



**COUNTY OF DANE**  
DEPARTMENT OF ADMINISTRATION  
**PURCHASING DIVISION**  
Room 425 City-County Building  
210 Martin Luther King Jr. Blvd.  
Madison, WI 53703-3345  
608-266-4131  
FAX 608-266-4425 TDD 608-266-4941

GREG BROCKMEYER  
Director of Administration

CHARLES HICKLIN  
Controller

DATE: February 22, 2018  
TO: All Proposers RFP# 118019 – Security Cameras, Installation, Software, and Service for the Alliant Energy Center Campus  
FROM: Megan Rogan, Purchasing Agent  
SUBJECT: ADDENDUM #2

The following answers are provided in response to questions received.

1. **Q: What kind of Fiber (single mode or Multi Mode) is between IDF's?**  
**A: All IDF's are connected via single mode fiber that is terminated to the existing switches.**
2. **Q: Are we to use the dark strands? If so, are they terminated?**  
**A: See answer #1.**
3. **Q: How many total existing cameras are in each building?**  
**A: Coliseum = 1 camera**  
**Exhibition Hall = 31 cameras**
4. **Q: Will there be scaled CAD drawings available at any point to use for bidding?**  
**A: There are no CAD drawings available. The drawings previously supplied are to scale, exact camera placement will be determined by the vendor and demonstrated in vendor responses to Section 5.3: Map of Cameras and Other Hardware and Section 5.4: Map of Camera Coverage.**
5. **Q: In exposed ceilings does cable need to be in conduit?**  
**A: The cable in exposed ceilings does not need to be conduit.**
6. **Q: In drop ceilings, is it acceptable to use j hooks to run the cable?**  
**A: It is acceptable to use j hooks in drop ceilings.**
7. **Q: Is the existing guard shack camera IP or Analog?**  
**A: There is currently no camera at the guard shack.**
8. **Q: Is there any way to identify which cameras are existing vs. new on the drawings provided?**  
**A: A map is provided as part of this addendum. All existing camera locations are highlighted in blue.**

**9. Q: Can you provide a map showing the existing network locations at the Coliseum?**


**A: A map is provided as part of this addendum.**

Please acknowledge receipt of this addendum by noting "Addendum #2 Received" on the bottom of the Signature Affidavit when you submit your proposal. If you have any questions regarding this addendum, please contact me at 608-283-1487.

Sincerely,


Megan Rogan  
Purchasing Agent

Blue = Existing Camera Locations




Full 1st Floor  
css 2018

50 Feet




2nd Floor Meeting Rooms




ALLIANT  
ENERGY  
CENTER

JOHN  
J. HARRIS



**Main Concourse**  
**css 2018**


20 Feet L\_J



## Pavilion+ Prefunction + Upper Mezzanine

css 2018

20 Feet




Pavilion 2  
CSS 2018

50 Feet



# Alliant Energy Center Coliseum IDF Fiber Runs



Coliseum Arena Level

20 Feet L\_J

CSS 2018