



**COUNTY OF DANE**  
DEPARTMENT OF ADMINISTRATION  
**PURCHASING DIVISION**

City County Building  
210 Martin Luther King Jr. Blvd. Room 425  
Madison, WI 53703-3345

**GREG BROCKMEYER**  
Director of Administration

**CHARLES HICKLIN**  
Controller

Date: November 25, 2020  
To: All Proposers  
Subject: Addendum #3 to Bid# 120072 – Renewable Gas Plant Media

**The following questions were received and responses are provided:**

1. What testing is required to verify absorption of the media?  
Each vendor must propose an analytical method or methods for effectively analyzing the removal efficiency and/or loading rate of the proposed media and benchmarking performance to ensure that appropriate change out frequencies are established. This should be outlined in a separate attachment added to the pricing proposal section of the bid response.
2. The ranges for VOC and siloxanes concentrations are extremely broad, spanning orders of magnitude in range. It is not real data we can use to estimate bed life. Is there any actual gas analysis data they are basing the concentrations on in the bid package? Also, if they have siloxane/VOC units prior to H<sub>2</sub>S polishing, is the gas saturated or undergoing any dehydration?  
The incoming gas quality varies and the ranges are based on actual data. For the purposes of this bid, use the average of the range provided for estimating life of the VOC media. Please provide any limitations in the media's ability to remove parameters at the levels indicated. The gas is dehydrated prior to the H<sub>2</sub>S and VOC polishing vessels (Applications 2 and 3).

Please acknowledge receipt of this addendum by checking the "Addendum #3" box in **Section 2 – Vendor Information** of your bid submission. If you have any questions regarding this addendum, please contact me via phone or email as listed below.

Sincerely,

Pete Patten  
Purchasing Agent  
608-267-3523  
patten.peter@countyofdane.com